




China Ceprei (Sichuan) Compliance Laboratory  
TEL: 0086-28-85221721 FAX: 0086-28-85224532

## ATTESTATION OF CONFORMITY

CE ATTESTATION OF CONFORMITY is hereby issued to certify the following equipment

**Certificate Holder:** ZHEJIANG CHINT ELECTRICS CO., LTD.

**Address:** CHINT HIGH-TECH INDUSTRIAL ZONE, NORTH  
BAIXIANG, WENZHOU, ZHEJIANG, P.R.CHINA

**Certification Marking:** 

**Product Type:** Residual Current Operated Circuit Breaker

**Product Model:** DZ158LE-100

**Parameters:** Rated Voltage: ~230V, ~400V  
Rated Frequency: 50Hz  
Rated Current: 63-100A  
Pole: 1P+N, 2P, 3P, 3P+N, 4P  
Rated residual operated current: 0.03, 0.1, 0.3A

**Certificate Number:** EU 02 031143 05


**Test Report Number:** 252333999

**Date of Issuance:** June 21, 2005

Complied with the requirement set out the Council Directive  
73/23/EEC (Low Voltage Directive). Amended Directive 93/68/EEC.

The following standard were applied:

EN 60947-2: 2003, IEC 60947-2: 2003

Signature:   
Bill Shi

Title: Engineer Manager

