




China Ceprei (Sichuan) Compliance Laboratory
TEL: 0086-28-85221721 FAX: 0086-28-85224532

ATTESTATION OF CONFORMITY

CE ATTESTATION OF CONFORMITY is hereby issued to certify the following equipment

Certificate Holder: ZHEJIANG CHINT ELECTRICS CO., LTD.

Address: CHINT HIGH-TECH INDUSTRIAL ZONE, NORTH
BAIXIANG, WENZHOU, ZHEJIANG, P.R.CHINA

Certification Marking: 

Product Type: Residual Current Operated Circuit Breaker

Product Model: DZ267L-32

Parameters: Rated Voltage: ~230V
Rated Frequency: 50Hz
Rated Current: 6~32A
Rated Residual Operating Current: 0.03, 0.1, 0.3A
Instantaneous Tripping Type: C , D

Certificate Number: EU 02 031143 06


Test Report Number: 252334000

Date of Issuance: June 21, 2005

Complied with the requirement set out the Council Directive
73/23/EEC (Low Voltage Directive). Amended Directive 93/68/EEC.

The following standard were applied:

EN 61009-1: 2004, IEC61009-1:2003

Signature: 

Bill Shi

Title: Engineer Manager

